

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7170-0694:202 Page 1 of 1

CATEGORY: Control Unit (High-Rise)

LISTEE: Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02451-1133
Contact: Anthony J. Shalna (781) 471-3000*

DESIGN: Model 7200 MICRO high-rise fire alarm control unit. The unit consists of listed Model 7200 MICRO control unit (CSFM 7165-0694:203) and Model FireVac III voice communication system (CSFM 6911-0694:129) to form a high rise system. Power-limited; coded, noncoded or marchtime, local; auxiliary, remote station, central station and proprietary signaling system; waterflow, releasing device and sprinkler supervision. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

SPSU	Power Supply
KDU-M, KDU-LM	Keyboard Display Unit
ALU-M	Analog Loop Unit
SCU-M	System Control Unit
CAB-A	Enclosure
RAU, RAUFV	Remote Annunciator
AMM-2, -4, 4S	Monitor Module
AOM, AOM-2	Output Module

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a high rise fire alarm control unit for use with Model FireVac III voice evacuation system and separately listed compatible initiating and indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition. Refer to manufacturer's Installation Manual for details.

*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 21, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**